

QUARTERLY SAFETY WALK THROUGH
ABC Wastewater Treatment Facility
AnyWhere, New Hampshire

Date: 4/30/08

Weather Conditions: Sunny, Dry

Names of Inspectors: Joe Smith, John Doe

Item No.	Description of Findings	Recommendation/Implementation Plan
1	Hose Across Primary Building Stairs	Roll up hose and mention at next Ops / Maintenance Meeting
2	Extension cord in Maintenance area has frayed insulation	Replace cord
3	oil on floor next to Blower #1 in Aeration Building	Remove oil & check Blower for leaks
4		
5		
6		
7		
8		
9		
10		